





Features:

- 100-240V AC input
- Single Output
- 85% high efficiency
- 100% full load bur-in test
- Protection: OTP,OLP,OVP,SCP
- CE ROHS Certified
- 3 year warranty

Applications:

- Outdoor LED lighting
- · LED office lighting
- · LED commercial lighting
- LED decorative lighting


Specifications


| Product Code | | LP150-W1V12 | LP150-W1V24 |
|--------------|-----------------------------|---|-------------|
| Output | DC Voltage | 12V | 24V |
| | Rated Current | 12.5A | 6.25A |
| | Current Range | 0~12.5A | 0~6.25A |
| | Voltage tolerance | ±5% | ±5% |
| | Rated Power | 150W | 150W |
| | Ripple & Noise | <120mVp-p | <150mVp-p |
| | Set-up, Rise , Hold-up Time | 200ms, 100ms , 30ms | |
| Input | Input voltage range | 100-240 VAC | |
| | Frequency Range | 50~60Hz | |
| | AC Current | 1.7A / 115VAC; 0.85A / 230VAC | |
| | Efficiency | 85% | 88% |
| | PF | 0.6 | |
| Protection | Over Load | Above 105%-120% of rated power | |
| | | Shut-down output voltage, auto recovery after fault condition is removed | |
| | Over Voltage | Above Max. Voltage (105% of rated voltage) | |
| | | Shut-down output voltage, auto recovery after fault condition is removed | |
| | Over Temperature | Over 105°C detected on main IC control | |
| | | Shut-down output voltage, auto recovery after fault condition is removed | |
| Ambiant | Working Temp. & humidity | "-20°C~+60°C, 20%~90%RH | |
| | Storage temp. & humidity | "-40°C~+85°C, 10%~95%RH | |
| Tesings | Withstand voltage | I/P-O/P: 1.5KVAC/1min; I/P-F/G: 1.5KVAC/1min; O/P-F/G: 0.5KVAC/1min; | |
| | Safety | GB4943 ;IEC60950-1; EN60950-1 | |
| | EMC | EN 55032:2015+A11:2020 EN IEC 61000-3-2:2019+A1:2021 EN 61000-3-3:2013+A2:2021 EN55035:2017+A11:2020 | |
| | LVD | EN60950-1:2006+A11:2009+A1:2010+A12:2011+A2:2013 | |
| Others | Demension(L*W*H) | 192*52*37mm | |
| | Packing | 0.64kg/pcs, 25pcs/15kg/CTN | |


Mechanical Structures



Wiring Diagram







Notes:

- 1. The above mentioned data were measured at 230VAC input and 25°C.
- 2. Dis-connect the AC input before checking any mal-phenomenons.
- 3. Make sure the INPUT&OUPUT were in right situation before connected to power supply.
- 4. Datesheet for reference only. We suggest you take sampling before mass orders.